



Technical Bulletin 128

Basic Aeration Design
Calculations

by:

Environmental Dynamics International
Published: 1/2017

DISCLAIMER



Environmental Dynamics International, headquartered in Columbia, Missouri, USA, presents these Technical Bulletins as a service to our customers.

For more information regarding this bulletin or your specific aeration application, contact Environmental Dynamics International at +1 (573) 474-9456



Aeration requirements are usually developed from basic process design data applicable to each site. We have provided common air calculations in the examples below.

Example Number 1

Known data:

- Population: 3,000
- Typical domestic wastewater
- Allow 0.2 lb BOD/person per day (0.0972 kg/person)
- Allow 2 lb O₂/lb BOD (2 kg/kg) to accommodate some nitrification when NH₃ (ammonia) concentration is not known.

Oxygen Calculations

Estimated field O₂ requirement for extended aeration:

- $O_2/\text{day} = 3000 \text{ persons} * 0.2 \text{ lb BOD/person} * 2 \text{ lb O}_2/\text{lb BOD} = 1,200 \text{ lb O}_2/\text{day}$
(544.32kg/day)
- $O_2 \text{ required} = 50 \text{ lb O}_2/\text{hr} = 22.68 \text{ kg O}_2/\text{hr} = \text{field or process conditions} = \text{AOR}$
- Oxygen Transfer SOTE = 18% at 10 ft Diffuser Submergence (typical) = SOTE (5.5% per meter and 3.05m diffuser submergence)
Note: SOTE increases as air/diffuser is reduced.
- Assumed AOR/SOR* = 0.45 (typical correction for clean water efficiency to field efficiency). This value is calculated from site elevation, process, DO level in the tank, temperature, and density of diffusers.
- $\text{SOR} = 50 \text{ lb/hr}/0.45 = 111.72 \text{ lb/hr} (50.68 \text{ kg O}_2/\text{hr})$
- $\text{Air} = 111.72/1.044 * 0.18 = 595 \text{ SCFM} (942 \text{ Nm}^3/\text{hr})$
Note: SCFM = Standard Cubic Foot of Air per Minute. 1 SCFM of air equals 1.584 Nm³/hr or approximately 1.7 Sm³/hr.

*Note: For process calculations of AOR/SOR, see EDI's computerized Design Brief procedures or Integrated Diffused System Analysis Procedures. Calculations are available upon request from EDI.

Example Number 2

Known data:

- Municipal waste – Conventional activated sludge
- Flow – 5 mgd (18,931 m³/day)
- BOD – 250 mg/l
- NH₃ (ammonia) – 30 mg/l
- Process O₂ requirements
 - o 1.2 lb O₂/lb carbonaceous BOD (1.2 kg O₂/kg of BOD)
 - o 4.6 lb O₂/lb NH₃ (4.6 kg O₂/kg of ammonia)
 - o % SOTE = 18% @ 10 ft diffuser submergence (clean water efficiency) (5.5% per meter and 3.05 m submergence)
 - o Assumed AOR/SOR = 0.45 (typical correction for clean water efficiency to field efficiency)

Oxygen Calculations

Process or field O₂ for carbonaceous BOD:

- $5 \text{ mgd} * 8.34 * 250 \text{ mg/l} * 1.2 \text{ lb O}_2/\text{lb BOD} = 521.25 \text{ lb O}_2/\text{hr AOR} (236.5 \text{ kg O}_2/\text{hr})$
- $\text{SOR} = 521.25/0.45 = 1,158.4 \text{ lb O}_2/\text{hr} (525.4 \text{ kg O}_2/\text{hr})$
- $\text{Air for Carbonaceous} = 1,158.4/1.044 * 0.18 = 6,165 \text{ SCFM} (9,765 \text{ Nm}^3/\text{hr})$
- $\text{O}_2 \text{ for ammonia} = 5 \text{ mgd} * 8.34 * 30 \text{ mg/l} * 4.6 \text{ lb O}_2/\text{lb NH}_3 = \text{AOR}$
 - o $\text{AOR} = 5,754.6 \text{ lb/day} (2,610.3 \text{ kg O}_2/\text{day})$
 - o $\text{SOR} = 5,754.6/0.45 = 12,788 \text{ lb O}_2/\text{day} = 532.9 \text{ lb/hr} (241.72 \text{ kg O}_2/\text{hr})$
- $\text{Air for ammonia} = 532.9 \text{ lb/hr}/1.044 * 0.18 = 2,836 \text{ SCFM} (4,492 \text{ Nm}^3/\text{hr})$
- $\text{Total air} = \text{Carbonaceous} + \text{Nitrogenous} = 6,165 \text{ SCFM} + 2,836 \text{ SCFM} = 9,601 \text{ SCFM} (16,562 \text{ Nm}^3/\text{day})$

Note: SCFM = Standard Cubic Foot of Air per Minute. 1 SCFM of air equals 1.584 Nm³/hr or approximately 1.7 Sm³/hr.

Calculating air volumes allows confirmation of design and blower selections. For Integrated Diffused Aeration Systems analysis and optimization, EDI conducts a more rigorous evaluation.

